



Drinking Water System

2019 - Annual Report

322 Water Street
Deseronto, Ontario
K0K 1X0

Prepared: January 2020

Executive Summary

Major upgrading of the Town of Deseronto Water Treatment Plant continued into 2019. A full replacement of the treatment process was completed by the end of April 2019. The third and final filter went online as of April 4, 2019 followed by the second and final DAF unit going online April 29, 2019. Refurbishment of the building interior/exterior continued and in early 2020 they are proceeding with minor cosmetic deficiencies. The new treatment process utilizes coagulation / flocculation and dissolved air flotation, followed by conventional sand / GAC filtration, and chlorine disinfection. The upgrades eliminate historic capacity limitations, making the process capable of processing the permitted 2,946 m³/d of raw water.

During 2019, the average treated water pumped to the community of 1073 m³/day represents a decrease of approximately 10 percent when compared to 2018. The 2019 maximum day flow of 1931 m³/d occurred in August as the result of flushing of hydrants in the distribution system. The 2019 maximum day flow represents approximately 66 percent of the design capacity while the average day flow represented approximately 38 percent of design capacity.

Water samples collected throughout the process at varying frequencies are tested for approximately 70 different parameters to evaluate treatment efficiency and to ensure finished water quality. All samples met the requirements of the Ontario Drinking Water Quality Standards.

Table of Contents

Executive Summary i

Table of Contents ii

Key Words & Terms iv

Introduction 1

1 - Description of the Deseronto Water Treatment Process 2

 1.1 Origins and Types of Raw Water Contaminants2

 1.2 Raw Water Supply.....2

 1.3 Coagulation / Flocculation / Dissolved Air Floatation3

 1.4 Filtration3

 1.5 Chlorination / Disinfection4

 1.6 Elevated Storage Tank.....4

 1.7 Process Waste Residual Treatment.....5

 1.8 Multiple Barriers to Microbiological Pathogens5

 1.9 Laboratory Testing5

 1.10 Alarms and Staffing.....5

2 – Reports of Adverse Water and Other Deficiencies 7

3 - Flow Measurement and Analytical Results.....8

 3.1 Raw and Treated Water Flow8

 Table 1 – Raw and Treated Water Flow8

 3.2 Temperature, Colour, Alkalinity, pH, and Hardness10

 Table 2 – Temperature, pH, Alkalinity, Hardness, and Colour.....10

 3.3 Turbidity12

 Table 3 – Raw, Filtered, and Treated Water Turbidity13

 3.4 Disinfection and Bacteriological Testing14

 Table 4a – Treated Water Disinfection and Bacteriological Analytical Data15

 Table 4b – Distribution Water Disinfection and Bacteriological Data16

 Table 4c – Raw Water Pre-chlorination and Bacteriological Data17

 3.5 Process Chemical Addition17

 Table 5 – Treatment Process Chemical Use and Aluminum Residual.....18

 3.6 Other Organic and Inorganic Testing18

Table 6 – Schedule 23, Fluoride, Sodium, Nitrite, and Nitrate	19
Table 7 – Schedule 24 Parameter Concentration Data.....	20
Table 7 – Schedule 24 Parameter Data (2).....	21
3.7 Distribution System Lead Testing	22
Table 8 – Distribution Lead, pH, and Alkalinity.....	23
3.9 Microcystin Testing.....	23
3.10 Waste Clarifier Performance Monitoring	24
Table 9 – Waste Clarifier Performance Data	24
4 – System Maintenance and Improvements	25

Key Words & Terms

m³ /d	cubic metres per day, (1m ³ = 1000 litres)
mg/L	milligrams per litre, (1 part in 1,000,000)
µg/L	micrograms per litre, (1 part in 1,000,000,000)
ACU	apparent colour measurement units (standard unit to quantify colour in water)
NTU	nephelometric turbidity units (standard unit to quantify turbidity in water)
MAC	maximum acceptable concentration
IMAC	interim maximum acceptable concentration
AO	aesthetic objective (non-health related)

Coagulation / Flocculation refer to the water treatment chemical processes that convert small particles of suspended solids into larger, more settleable or floatable clumps.

Disinfection refers to the process that destroys disease-causing organisms in water, usually by the addition of chlorine.

Escherichia Coli (E. Coli) refers to a subgroup of fecal coliform bacteria that reside in the digestive systems of warm blooded animals. The presence of *E. Coli* in drinking water is a strong indicator of fecal contamination. *E. Coli* is rapidly destroyed by chlorine.

Heterotrophic Plate Count (HPC) is a microbial test method that quantifies levels of heterotrophic bacteria. Most bacteria, including those common in drinking water systems, are heterotrophs. Increases in the density of HPC bacteria in the distribution system are usually the result of bacterial re-growth which is influenced by the quality of the water entering the system, temperature, flow (i.e. stagnation), presence of a disinfectant residual, construction materials, and the availability of nutrients for growth. HPC in drinking water are not considered a direct health threat.

Inorganic refers to non-carbon based substances. Common inorganic substances in water include metals, minerals, nutrients, and salts.

ODWQS refers to the Ontario Drinking Water Quality Standards. The ODWQS define the standards, objectives, and guidelines to be followed for the provision of a safe and aesthetically acceptable drinking water supply.

Ontario Regulation 170/03 or O.Reg.170/03 refers to the Drinking Water Systems Regulation as amended.

Ontario Regulation 169/03 or O.Reg.169/03 refers to the ODWQS Regulation as amended.

Organic refers to a large group of carbon-based chemical compounds including all animal and vegetable matter plus many synthetic compounds such as pesticides and industrial solvents.

Raw Water is defined as surface (lakes, rivers) or ground water (wells) available as a source of drinking water that has not received any treatment.

Dissolved Air Flotation (DAF) refers to the treatment process that involves the use of microbubbles released from air saturated water to float flocculated suspended material to the surface of a flotation tank for removal by skimming.

Total Coliform Bacteria are a group of commonly occurring, mostly harmless bacteria that live in soil and water as well as the gut of animals. Their presence in a water sample may be indicative of inadequate filtration and/or inadequate disinfection.

Turbidity refers to a physical characteristic of water that causes a cloudy appearance. Turbidity is caused by the presence of suspended matter. The substances that cause turbidity can be a source of disease causing organisms and can shield potentially pathogenic organisms from disinfection.

THM's / HAA's refer to trihalomethanes and haloacetic acid compounds which are disinfection by-products formed when chlorine combines with organic substances in the water supply. Elevated concentrations are carcinogenic.

Introduction

The 2019 Annual Report for the Deseronto Water Treatment Plant summarizes treated water quality and process operating data with reference to the requirements of Ontario Regulation 170/03 (O. Reg. 170/03), Ontario Regulation 169/03 (O. Reg. 169/03), Municipal Drinking Water Licence 154-101, Drinking Water Works Permit 154-201, and Permit to Take Water 6262-98DPFG. This report consolidates the reporting requirements specified as “Annual Report” in O.Reg.170/03, Sec. 11, and “Summary Reports for Municipalities” in O.Reg.170/03, Schedule 22.

- Section 1 of the report provides a description of the water treatment process.
- Section 2 summarizes reports to the Ministry of the Environment, Conservation and Parks (MECP) under Subsection 18(1) of the Safe Drinking Water Act (notices of adverse water quality) or Schedule 16, Section 16-4 of O. Reg.170/03 (notice of inadequate disinfection).
- Section 3 summarizes process data including: accredited laboratory and “in-house” water quality laboratory testing, process flow measurement, and treatment process chemicals.
- Maintenance and upgrading projects carried out during 2019 are discussed in Section 4.

Copies of the Annual Drinking Water Report are available to the public free of charge from Deseronto Town Hall at 331 Main Street in Deseronto. Reports are also available on-line at <https://www.deseronto.ca/residents/waterwaste-water/>.

Additional information on drinking water standards in Ontario is available from the MECP at: <https://www.ontario.ca/page/drinking-water>.

The Town of Deseronto is an accredited operating authority, conforming to the Ontario Drinking Water Quality Management Standard.

DWQMS Policy: The Town of Deseronto is committed to the supply of safe, reliable municipal drinking water and to abiding by all applicable legislation and regulations. That commitment is sustained by our dedication to the implementation, maintenance, and continual improvement of a Quality Management System that conforms to the Ontario Drinking Water Quality Management Standard.

1 - Description of the Deseronto Water Treatment Process

1.1 *Origins and Types of Raw Water Contaminants*

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity.

The types of contaminants that may be present in raw water include:

- Microbiological contaminants, such as pathogens, may come from septic systems, livestock, sewage treatment plants, and wildlife. Microbiological quality is the most important component of drinking water quality because of its ability to cause acute illness in consumers.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Organic contaminants can be naturally occurring, but most organic compounds of concern are man-made. Pesticides and herbicides are included in this group and may originate from a variety of sources such as agriculture, urban storm water runoff, and septic systems.

To ensure that tap water is safe to drink, the Ontario Ministry of the Environment, Parks and Conservation (MECP) prescribes treatment, monitoring, and reporting standards that apply to all drinking water systems in the Province.

The following describes the Deseronto treatment process and the monitoring that takes place to ensure the safety of our drinking water.

1.2 *Raw Water Supply*

Water is drawn from the Bay of Quinte through a 400 mm diameter intake pipe, extending 490 m off-shore, submerged to a depth of approximately 6 m. Coarse screens at the intake crib and at the inlet to the low lift pumping station prevent large debris from passing into the treatment process. Following the screens, raw water flows by gravity into a tank at the low lift pumping station from where it is pumped to the treatment process.

1.3 Coagulation / Flocculation / Dissolved Air Floatation

Raw water pumped to the treatment plant first enters the dissolved air floatation (DAF) treatment units (2). DAF equipment includes two saturation tanks, duplex air compressor and tank, recirculation pumps (3), two-stage flocculation tanks (2), floatation tanks (2), float skimmer mechanisms (2), and float discharge hopper (2). The DAF units are operated in a parallel configuration.

Coagulants are injected into the raw water immediately upstream from the two-stage flocculation tanks. Coagulants are chemicals that cause the gathering of small colloidal and suspended material present in the raw water (measured as turbidity) to form more stable and distinct particles. Rapid mixing of the primary coagulant with the raw water occurs as the raw water passes through a static mixer. The raw water then enters the flocculation tanks where polymer is added, and gentle mixing takes place to promote the formation of sticky flock particles (flocculation). At the downstream end of the flocculation tanks, flow passes under a baffle to the DAF reaction zone and floatation tank. In the reaction zone a steady flow of air saturated water is distributed through a nozzle header, recycled from the effluent end of the floatation tank. Microscopic bubbles are released from the air saturated stream which adhere to the particles formed in the flocculation tanks and floats them to the surface of the floatation tank. The accumulated material on the surface of the floatation tank is referred to as float. The float is skimmed from the surface of the floatation tank and directed to a waste holding tank. The clear water below the float passes under a baffle, over a weir and on to the filtration process.

1.4 Filtration

The Deseronto WTP has three parallel gravity dual media filters, utilizing sand and granular activated carbon (GAC) media. Residual particulate matter carried over from the floatation process is trapped primarily in the sand portion of the filter. The GAC is effective in removing organic compounds, many of which are responsible for unpleasant taste and odour sometimes experienced during the warmer months. Filtered water passes through under-drain nozzles, located at the bottom of the filter media. The under-drain nozzles are designed to allow the passage of water while retaining the filter media.

Turbidity, a measure of the cloudiness of water, is measured continuously in the effluent from each

filter to monitor the effectiveness of the filtration process. If the turbidity rises above a set-point value, the plant automatically shuts off and an alarm warns staff that corrective actions are needed.

Accumulated debris on the filter media must be periodically removed by backwashing. During backwashing, a filter is isolated from the treatment process while water is forced in a reverse direction through the media. Compressed air is also introduced to agitate the media surface, loosening accumulated debris. The backwash flow flushes the accumulated debris to a waste holding tank.

1.5 Chlorination / Disinfection

Chlorine is typically added to the process in two locations; the raw water to control the accumulation of zebra mussels and other biological growth; and to the treated water for disinfection.

The addition of chlorine to the raw water is considered a pre-treatment measure and is referred to as pre-chlorination. Pre-chlorination can be applied at the intake crib (normal point of application) or into the low lift pump discharge header.

The intake crib was last inspected and cleaned in June of 2016. The inspection report confirmed successful operation of the zebra-mussel control system.

The second point of chlorine addition occurs at the treatment plant, immediately downstream from the dual media filters and GAC contactors and is referred to as post-chlorination. Post-chlorination disinfects the treated water, ensuring that any remaining, potentially pathogenic organisms are inactivated prior to entering the distribution system.

Sufficient chlorine is added at the treatment plant to maintain a residual concentration throughout the distribution system. Maintaining chlorine residual throughout the distribution system is referred to as secondary disinfection. Secondary disinfection is a regulated requirement which is necessary to prevent the growth of micro-organisms in the distribution system.

1.6 Elevated Storage Tank

Treated water is pumped from the clearwells into the distribution system. The treated water storage standpipe is connected to the distribution system grid. The 1135 m³ standpipe provides relatively

constant system pressure and a reserve volume of water for community fire protection.

1.7 Process Waste Residual Treatment:

Waste residuals generated through the treatment process, including filter backwash, settled floc removed from the reactor clarifier, and float skimmed from the DAF are directed to the waste holding tank. Wastewater from the holding tank is either pumped to the waste clarifier for treatment, or directly to the municipal wastewater treatment plant. The waste clarifier separates the waste stream solids by gravity sedimentation. The settled solids are pumped to the municipal wastewater treatment plant, and the treated overflow from the top of the clarifier is discharged to the Bay of Quinte.

1.8 Multiple Barriers to Microbiological Pathogens:

Potentially pathogenic organisms are removed from the raw water source by the following processes:


- pre-chlorination
- flocculation / dissolved air flotation
- filtration
- post-chlorination
- distribution system chlorine residual (secondary disinfection)

1.9 Laboratory Testing:

Ontario Regulation 170/03 dictates the sampling and monitoring requirements for the Deseronto facilities. Water quality is tested routinely throughout the treatment process and at the extremities of the distribution system. Analytical testing is conducted by an accredited laboratory.

1.10 Alarms and Staffing:

The Deseronto Water Treatment Plant is staffed during daytime hours on weekdays and is visited on weekends and holidays for routine system checks. During off-hours, process irregularities or building security breaches are detected by the plant alarm system and relayed to an on-call operator 24 hours per day, 7 days per week.



2 – Reports of Adverse Water and Other Deficiencies

Based on monitoring and sample results recorded in 2019, there were no indications of adverse water quality or other deficiencies observed.

3 – Flow Measurement and Analytical Testing

3.1 Raw and Treated Water Flow

Raw water is pumped to the treatment facility from the Bay of Quinte in accordance with the terms and conditions of Permit to Take Water 6262-98DPFG (expires June 1, 2023). During 2019, the permitted maximum day flow of 2946 m³/d and maximum instantaneous flow of 2050 L/min were not exceeded. Raw water flow to the treatment process averaged 1122 m³/d, with a maximum day flow of 1931 m³/day recorded on October 29th.

Raw and treated water flow data for 2019 are summarized in Table 1.


Table 1 – Raw and Treated Water Flow

Month	Raw Water				Treated Water			
	Minimum Daily Flow (m ³ /d)	Maximum Daily Flow (m ³ /d)	Average Daily Flow (m ³ /d)	Total Monthly Flow (m ³)	Minimum Daily Flow (m ³ /d)	Maximum Daily Flow (m ³ /d)	Average Daily Flow (m ³ /d)	Total Monthly Flow (m ³)
January	968	1363	1139	35308	904	1284	1099	34065
February	1006	1408	1153	32297	966	1274	1097	30715
March	992	1383	1153	35735	905	1280	1090	33791
April	959	1259	1121	33638	919	1214	1074	32216
May	971	1408	1172	36321	913	1223	1091	33832
June	1023	1396	1214	36424	965	1318	1157	34721
July	1105	1489	1298	40235	1037	1467	1242	38499
August	895	1931	1206	37377	912	1861	1158	35887
September	933	1377	1123	33678	837	1391	1078	32350
October	767	1251	964	29891	727	1166	929	28812
November	778	1097	937	28096	767	1072	904	27123
December	750	1201	988	30626	742	1136	959	29724
Year Avg.			1122				1073	
Year Total				409627				391735
Year Max./Min.	750	1931			727	1861		
Permitted Capacity						2946		
Permit to Take Water		2946						

Treated water production averaged 1073 m³/d, which is approximately 10 percent less than the 2018 average day flow. The maximum day treated water flow recorded during 2019 was 1861 m³/d, representing 63 percent of the permitted plant capacity of 2946 m³/d.

Treated water average and maximum day flows for each month of 2016, 2017, 2018 and 2019 are shown in the chart below.

Limitations to treated water production were experienced on the original process at the reactor clarifier and at the filters, particularly during backwash cycles. The working capacity of the original system is depicted on the chart at approximately 1600 m³/day. Upgrades to the process which commenced in 2018 and completed in 2019 eliminated those bottlenecks and restored the process to the original design capacity of 2946 m³/d. This is shown on the chart as of May 2019.



Maximum treated water demand was observed in August 2019. The cause is due to annual hydrant flushing in the distribution system. During 2019, there were two service leaks and no watermain break repairs. Repair or PM replacement of two customer service valves was also completed in 2019. With the increased capacity, eight new connections were made in the Town. Two ¾” connections for a duplex and five ¾” connections to serve a ten-plex along with a 2” service to feed a five-plex.

Locations of service leaks and main breaks can go undetected for extended periods of time as they often start slow and become worse over time. System leaks are typically located when water is observed on the surface of the ground or when customers report low pressure or noise from their service lines. Leaking water doesn't easily surface due to the drainage provided by the fractured limestone geology underlying the Town. Undetected service breaks impose a significant burden on plant capacity. Single service leaks can waste as much as 20 percent of an average day of production.

The raw and treated water flow meters are calibrated annually by a qualified technician.

3.2 Temperature, Colour, Alkalinity, pH, and Hardness

Temperature, colour, alkalinity, and pH are measured in raw and treated water typically twice each week and are summarized for 2019 in Table 2. All are related to the operation of the coagulation and flocculation processes. Temperature and pH are also related to the effectiveness of the disinfection process. Hardness is a measure of dissolved minerals in water and is also included in Table 2. At elevated levels, hardness can create scaling on pipes, plumbing fixtures, and appliances.

Table 2 – Temperature, pH, Alkalinity, Hardness, and Colour

Month	Raw Water				Treated Water				
	Temp. (C)	pH	Alkalinity (mg/L CaCO ₃)	Colour (ACU)	Temp. (C)	pH	Alkalinity (mg/L CaCO ₃)	Hardness (mg/L)	Colour (ACU)
January	2.8	7.85	99	48	2.8	7.41	85	113	0
February	2.9	7.84	109	36	2.6	7.40	89	115	0
March	3.4	7.65	94	31	3.1	7.18	85	111	0
April	7.4	7.78	108	55	7.1	7.14	88	103	0
May	13.0	7.76	102	45	12.9	7.10	81	100	0
June	17.9	7.60	92	52	18.0	7.14	89	111	0
July	20.6	7.79	96	45	20.1	7.12	93	122	0
August	22.5	7.91	100	69	23.0	7.11	94	113	4
September	20.3	7.88	106	71	20.8	7.08	87	106	0
October	15.7	7.80	90	40	15.9	6.94	82	113	0
November	8.1	7.89	89	65	8.9	7.10	79	115	0
December	4.1	7.85	114	44	4.9	7.14	93	109	0
Annual Avg.	11.6	7.80	100	50	11.7	7.16	87	111	0.3
Aesthetic Obj.					<15	6.5 - 8.5	30 - 500	80 - 100	5

Notes: -Aesthetic Obj. - refers to non-health related objectives from the ODWQS

-Expressed as monthly arithmetic mean values calculated from daily pH and temp (all others 2 samples/wk.)

Temperature: The data show that the raw water supply varies significantly in temperature over the course of the year. Raw and treated water temperatures measured daily ranged from approximately 3 C to 23 C. Temperature extremes can present challenges to the treatment process as some chemical coagulants react less quickly in cold water. At the other extreme, warm water promotes the growth of plants and algae in the raw water source, requiring higher chemical dosages and the potential for increased frequency of filter backwashing for effective treatment.

Colour: Colour develops in raw water sources most often from the decay of naturally occurring organic matter. The resulting colloidal and dissolved organic compounds react with coagulant chemicals and tend to increase dosage requirements. At the treatment plant, colour is removed by chemical oxidation during pre-chlorination, in the coagulation / flotation process, and through the granular activated carbon contactors.

Monthly average raw water colour measurements ranged from 31 ACU to 71 ACU. Effective removal was achieved through the treatment process as colour did not exceed the aesthetic objective of 5 NTU in any treated water samples collected during 2019.

On August 19, 2019 there were several customer complaints regarding coloured water. This happened at the same time as the new watermain on College Street between Thomas Street and Dundas Street was put into service that may have changed flow characteristics in the Town. Also the annual flushing program hadn't been completed in 2019. The condition was corrected by adjusting the treatment process coagulant dosage and completing the annual hydrant flushing program.

pH: pH has an impact on the performance of coagulants and on the effectiveness of the disinfection process. Both raw and treated water pH values remained relatively stable and within an acceptable range, averaging 7.8 and 7.2 respectively.

Alkalinity: Closely related to pH, alkalinity is a measurement of the acid buffering capacity of water. (The higher the alkalinity, the more acid that can be added before a change in pH occurs.) Several substances naturally present in raw water are measured as alkalinity, the majority of which are carbonate compounds. Coagulants, when added to water, combine with the alkalinity to produce

insoluble metal hydroxides (floc particles) that play an important role in the flotation process. The primary coagulant used in the process is acidic and therefore decreases alkalinity. If too much natural alkalinity is consumed by the coagulant, there may be insufficient alkalinity remaining for optimal floc formation. Therefore, if a noticeable drop in pH (and alkalinity) is occurring, it may be necessary to lower the coagulant dosage to conserve alkalinity or alter the process by adding alkalinity to the incoming raw water.

Raw and treated water alkalinities were relatively consistent through 2019 averaging 100 mg/L and 87 mg/L, respectively. All treated water alkalinity measurements were within the ODWQS recommended operational range.

Hardness: Hard water can cause scaling in pipes and fixtures while water that is low in hardness tends to be corrosive. According to the ODWQS, the ideal range is between 80 and 100 mg/L. Testing of treated water from the Deseronto process indicated moderate hardness (marginal potential for scaling), averaging 111 mg/L. Hardness in water is not a health concern, but rather an aesthetic characteristic.

3.3 Turbidity

Turbidity refers to a physical characteristic of water that causes a cloudy appearance. Turbidity is caused by the presence of suspended matter. It is of concern in treated water as it may include disease causing organisms, or material that can shield pathogens from disinfection. Adequate removal of turbidity through the treatment process is therefore necessary to ensure the effectiveness of the disinfection process.

Table 3 is a summary of turbidity measured in raw water as it enters the plant, effluent discharged from each filter, and in treated water prior to entering the distribution system.

Table 3 – Raw, Filtered, and Treated Water Turbidity

Month	Raw Water Turbidity			Dual Media Filter #1			Dual Media Filter #2			Dual Media Filter #3			Treated Water Turbidity		
	Min	Max	Avg	Min	Max	Avg	Min	Max	Avg	Min	Max	Avg	Min	Max	Avg
January	0.57	2.47	1.12	0.02	0.33	0.04	o/s	o/s	o/s	o/s	o/s	o/s	0.05	0.29	0.09
February	0.67	2.72	1.05	0.02	0.21	0.03	0.03	0.09	0.05	o/s	o/s	o/s	0.05	1.00	0.07
March	0.51	2.09	1.03	0.02	0.25	0.03	0.03	0.39	0.04	o/s	o/s	o/s	0.05	0.36	0.07
April	1.05	2.59	1.93	0.03	0.16	0.04	0.03	0.16	0.05	0.03	0.17	0.05	0.05	1.00	0.08
May	0.97	2.21	1.47	0.04	0.30	0.06	0.02	0.30	0.06	0.03	0.34	0.09	0.04	1.01	0.07
June	1.10	1.42	1.26	0.06	0.22	0.09	0.06	0.24	0.08	0.04	0.23	0.07	0.00	1.00	0.10
July	1.71	4.14	2.47	0.08	0.27	0.15	0.01	0.28	0.11	0.07	0.33	0.10	0.06	1.00	0.11
August	4.00	7.01	4.78	0.00	0.24	0.08	0.05	0.33	0.07	0.06	0.30	0.09	0.00	1.00	0.16
September	2.27	5.59	4.20	0.07	0.17	0.08	0.05	0.45	0.08	0.06	0.19	0.07	0.06	1.00	0.07
October	0.99	2.76	1.62	0.07	0.17	0.08	0.06	0.18	0.06	0.06	0.18	0.06	0.06	1.00	0.08
November	1.11	10.30	3.24	0.06	0.16	0.07	0.01	0.13	0.05	0.04	0.13	0.05	0.04	1.00	0.08
December	0.83	1.45	1.28	0.06	0.14	0.07	0.03	0.11	0.04	0.03	0.14	0.05	0.00	1.00	0.04
Avg.			2.12			0.07			0.06			0.07			0.08
Max./Min.	0.51	10.30		0.00	0.33		0.01	0.45		0.03	0.34		0.00	1.01	
ODWS MAC														1.0	

Notes: Raw values are averages of grab samples collected 2x/wk and measured using a Hach 2100P portable turbidity meter
Dual media filters and treated turbidity values are continuous measurements

Raw (untreated) water turbidity, based on monthly averages of bench top measurements during 2019, indicated a source water of moderately variable clarity, averaging 2.12 NTU and ranging from 0.51 NTU to 10.3 NTU.

Filtered water turbidity measured continuously in the effluent from filters 1,2 and 3 averaged 0.07 NTU, 0.06 NTU and 0.07 NTU respectively. Maximum values were 0.33 NTU for filter 1 and 0.45 NTU for filter 2 and 0.34 NTU for filter 3. Filter turbidity measurements consistently met the requirements of the Ontario Drinking Water Quality Standards.

The rules for disinfecting drinking water require that at least 95 percent of filtered water turbidity measurements in a given month are less than 0.3 NTU. Calculations confirmed that the rule was satisfied during each month of 2019. Treated water turbidity was typically less than 0.1 NTU, averaging 0.08 NTU.

Process alarms are installed at various stages of treatment to alert staff to abnormally high turbidity well in advance of significant process failure or the compliance limit. In the event that turbidity exceeds an alarm set point, the low lift pumps automatically shut off, halting the treatment process until the abnormal operating condition is corrected.

Accuracy of the raw, process, and treated water continuous monitoring instruments is verified at least twice weekly using portable bench top instrumentation. Both continuous and bench top measurement instruments are routinely maintained and calibrated in accordance with manufacturer recommendations.

3.4 Disinfection and Bacteriological Testing

Disinfection of the water supply protects public health by ensuring the inactivation of potentially harmful micro-organisms that may have passed through the treatment process or entered the distribution system by other means. A minimum free residual of 0.2 mg/L, maintained throughout the distribution system, is recommended in the *Procedure for Disinfecting Drinking Water in Ontario*. Less than 0.05 mg/L free residual is considered an adverse condition and may pose a potential threat to public health. Additionally, the *Guideline* requires that treated water must be mixed with the disinfectant and held for a minimum period of time before distributing to customers. This is referred to as CT which is calculated as the product of the disinfectant concentration and the amount of time the water is exposed to the disinfectant. CT is directly related to the rate of pathogen inactivation.

Chlorine residuals are monitored continuously in raw water (upstream from the treatment process) and in treated water. The treated water analyzer is equipped with alarms that alert the operators to process abnormalities and will shut down the process to prevent improperly disinfected water from entering the distribution system.

Disinfectant residuals and bacteriological results are summarized in Tables 4a, 4b, and 4c. Chlorine residual measurement instruments are routinely calibrated and maintained by operations staff according to manufacturer specifications.

Table 4a – Treated Water Disinfection and Bacteriological Analytical Data

Month	Treated Water								
	Free Cl ₂ Residual			Total Cl ₂ Residual			Total Coliforms (org./100mL)	E. Coli (org./100mL)	Heterotrophic Plate Count (org./1mL)
	Min (mg/L)	Max (mg/L)	Avg (mg/L)	Min (mg/L)	Max (mg/L)	Avg (mg/L)			
January	0.97	1.96	1.45	1.44	1.81	1.63	0	0	<10
February	0.94	1.70	1.35	1.23	1.71	1.46	0	0	<10
March	0.95	1.87	1.47	1.22	2.03	1.67	0	0	<10
April	0.97	1.77	1.44	1.43	2.04	1.65	0	0	<10
May	1.21	1.53	1.41	1.44	1.72	1.57	0	0	<10
June	1.12	1.70	1.41	1.38	1.72	1.55	0	0	<10-10
July	0.98	1.79	1.41	1.39	1.80	1.61	0	0	<10
August	0.99	1.69	1.41	1.45	1.87	1.66	0	0	<10
September	0.44	1.68	1.41	1.40	1.82	1.55	0	0	<10-120
October	0.44	3.92	1.29	1.26	1.64	1.45	0	0	<10-10
November	0.96	1.45	1.24	1.10	1.57	1.39	0	0	<10-30
December	0.96	1.40	1.24	1.26	1.58	1.41	0	0	<10-20
# of samples	continuous			365	365	365	53	53	53
Annual Min/Max/Avg	0.44	3.92	1.38	1.10	2.04	1.55			

Notes:

- total chlorine residual values are derived from bench-top analysis of grab samples collected daily
- free chlorine residual values represent on-line continuous measurements recorded every 5 minutes.

Free chlorine residual measured in treated water at the plant averaged 1.38 mg/L, which is a little lower than the average of 1.59 mg/l observed in 2018. It is important to note that chlorine residual typically declines in proportion to the distance from the point of application. Relatively high chlorine residuals are required leaving the plant to ensure that the guideline minimum residual of 0.2 mg/L is maintained throughout the distribution system. Testing of approximately 150 grab samples collected from sample stations located at the distant extremes of the distribution system as well as continuous monitoring from one remote location indicate that the minimum free chlorine residual measured in the distribution system during 2019 was 0.38 mg/L.

Verification of the disinfection process is demonstrated by testing treated water samples for indicators of bacteriological contamination. Throughout 2019 over 200 water samples were collected at the water treatment plant and from various locations in the distribution system. There were no indications of adverse water quality measured in any sample collected in 2019.

Table 4b – Distribution Water Disinfection and Bacteriological Data

Month	Distribution Water					
	Distribution Free Cl ₂			Total Coliforms (org./100mL)	E. Coli (org./100mL)	HPC (org./1mL)
	Min (mg/L)	Max (mg/L)	Avg (mg/L)			
January	0.75	1.92	1.35	0	0	<10
February	0.70	1.47	1.17	0	0	<10-10
March	0.86	2.25	1.52	0	0	<10-10
April	1.21	1.88	1.50	0	0	<10-20
May	1.01	1.52	1.33	0	0	<10-10
June	0.81	1.69	1.30	0	0	<10
July	0.64	1.85	1.26	0	0	<10
August	0.61	1.84	1.31	0	0	<10
September	0.38	1.74	1.24	0	0	<10-10
October	0.45	1.62	1.18	0	0	<1010
November	0.57	2.09	1.34	0	0	<10
December	0.74	1.58	1.26	0	0	<10-10
# of samples	continuous			156	156	53
Annual Min/Max/Avg	0.38	2.25	1.31			

Notes:

Reported average and maximum free chlorine residual values represent continuous measurements recorded every 5 minutes

Reported minimum free chlorine residual values represent continuous measurements and analysis of grab samples collected from 3 locations each week

Samples for bacteriological testing are collected typically from 3 of 4 dedicated sample hydrants once each week

Raw water (untreated source water from the Bay of Quinte is chlorinated at the intake crib to control the growth of zebra mussels and to prevent other growth in the intake pipe prior to entering the treatment process. Chlorine residual in raw water is continuously measured immediately upstream from the treatment process to verify dosage. Grab samples of raw water are also collected daily and tested for free and total chlorine residual.

An underwater inspection and cleaning of the intake crib conducted in June 2016 indicated successful operation of the pre-chlorination / zebra mussel control system. The intake crib is inspected and cleaned at a frequency of every three to five years.

The bacteriological quality of raw water is routinely tested to detect changes in source water quality. Bacteriological quality tends to deteriorate when water temperature is warm due to increased rate of growth, and during heavy rainfall events when surface contaminants are washed into the source water. Raw water bacteriological results and chlorine residuals were relatively consistent with those observed in 2018.

Table 4c – Raw Water Pre-chlorination and Bacteriological Data

Month	Raw Water			Pre-chlorinated Raw Water					
	Total Coliforms (org./100mL)	E. Coli (org./100mL)	HPC (org./1mL)	Free Cl ₂ Residual			Total Cl ₂ Residual		
				Min (mg/L)	Max (mg/L)	Avg (mg/L)	Min (mg/L)	Max (mg/L)	Avg (mg/L)
January	0 - 13	0	70	0.02	0.16	0.07	0.12	0.25	0.18
February	0 - 4	0	30	0.02	0.25	0.10	0.00	0.40	0.20
March	0 - 12	0	30	0.02	0.19	0.08	0.16	0.25	0.19
April	0 - 10	0	10	0.01	0.13	0.06	0.02	0.21	0.12
May	4 - 13	0	10	0.03	0.08	0.06	0.06	0.15	0.10
June	0 - 10	0	1120	0.03	0.10	0.06	0.08	0.20	0.13
July	0 - 31	0 - 2	>2000	0.03	0.12	0.08	0.06	0.21	0.13
August	5 - 47	0 - 34	>2000	0.06	0.22	0.11	0.13	0.26	0.18
September	3 - 16	0 - 1	280	0.01	0.14	0.07	0.01	0.23	0.15
October	9 - 56	0 - 7	>2000	0.02	0.15	0.06	0.00	0.24	0.15
November	8 - 27	0 - 1	170	0.02	0.15	0.06	0.15	0.26	0.19
December	0 - 52	0	270	0.01	0.15	0.08	0.15	0.23	0.16
# of samples	53	53	12	365					
Min/Max/Avg				0.01	0.25	0.07	0.00	0.40	0.16
Range	0 - OG	0 - OG	20 - >2000						

Notes:

Reported free and total chlorine residuals are measured in daily grab samples

3.5 Process Chemical Addition:

Three chemicals are used in the treatment process including a poly-aluminum chloride blend, anionic polymer, and chlorine. Table 5 summarizes the use of those chemicals during 2019.

The average dosage of coagulant during 2019 was 34 mg/L (expressed as mg active ingredient/L), decreased by approximately 8 percent when compared to that observed in 2018 (37 mg/L).

Although dosage remained consistent with 2018, experience with the new process is required to optimize dosage and performance.

Polymer dosage in 2019 averaged 0.12 mg/L which was consistent with that observed in 2018 (0.14 mg/l).

Dissolved aluminum is measured in the treated water due to the necessary addition of aluminum-based coagulant in the treatment process. Optimized process control is recommended to reduce residual aluminum to under the operational guideline of 0.100 mg/L. High residual aluminum can cause scaling of the pipes in the distribution system, interference with certain industrial processes,

and re-flocculation in the distribution system. Aluminum residuals measured in treated water samples collected during 2019 averaged 0.019 mg/L showing a marginal decrease in the average observed the previous year (0.022 mg/L). Aluminum residual measurements did not exceed the ODWQS operational guideline. Monthly average treated water aluminum residuals are summarized in Table 5.

Table 5 – Treatment Process Chemical Use and Aluminum Residual

Month	Coagulant			Polymer		Pre Chlorine Gas		Post Chlorine Gas	
	Monthly Usage (L)	Average Dosage (mg/L)	Treated Water Al residual (ug/L)	Monthly Usage (L)	Average Dosage (mg/L)	Monthly Usage (kg)	Average Dosage (mg/L)	Monthly Usage (kg)	Average Dosage (mg/L)
January	2501	27.5	0.056	2339	0.13	19.5	0.55	93.0	2.74
February	1965	23.6	0.020	1897	0.12	14.5	0.45	95.6	3.12
March	2422	26.4	0.022	2054	0.12	10.1	0.28	106.4	3.16
April	2520	29.1	0.012	1653	0.10	11.2	0.34	87.0	2.70
May	2635	28.1	0.010	2239	0.12	12.4	0.35	83.4	2.46
June	3140	33.4	0.008	3238	0.15	12.2	0.34	102.4	2.96
July	3585	34.5	0.019	4539	0.11	11.8	0.29	103.6	2.70
August	3462	35.9	0.028	3792	0.10	13.6	0.36	106.0	2.97
September	3970	45.7	0.017	3487	0.10	15.2	0.45	85.8	2.66
October	3668	47.6	0.005	3103	0.16	14.0	0.47	68.0	2.36
November	2869	39.6	0.014	2956	0.11	12.1	0.43	70.6	2.61
December	2623	33.2	0.012	3154	0.10	13.7	0.45	76.0	2.55
Average	2947	33.7	0.019	2871	0.12	13.3	0.40	89.8	2.75
Year Total	35360			34451		160.1		1077.8	

The total mass of chlorine used in the treatment process decreased by approximately 10 percent when compared to 2018. Dosage of treated water distributed to customers remained relatively unchanged from 2018. The decrease in chlorine matches the decrease in total flow of 10%.

3.6 Other Organic and Inorganic Testing:

Analyses of approximately 70 additional organic and inorganic parameters in the treated water are required at various frequencies. The majority of those substances, listed as Schedules 23 and 24 in O.Reg.170/03, must be tested at least annually. Testing for nitrite, nitrate, THMs, and HAAs is required quarterly, while sodium and fluoride must be tested once every five years. The results of those analyses are summarized in Tables 6 and 7.

Concentrations of most tested substances were either below the analytical method detection limits (either not present or in trace levels too low to quantify) or well below the maximum acceptable concentrations listed in the ODWQS.

The 4-quarter average concentrations of THMs and HAAs (by-products of the disinfection process) in 2019 remained below the ODWQS maximum acceptable concentrations.

Table 6 – Schedule 23, Fluoride, Sodium, Nitrite, and Nitrate

Parameter	Limit mg/L	Limit Type	Date Sampled	# of samples	Treated Maximum Conc. mg/L	Limit Exceeded?
Antimony	0.006	IMAC	29-Jan-19	1	<0.0001	no
Arsenic	0.025	IMAC	29-Jan-19	1	0.0002	no
Barium	1	MAC	29-Jan-19	1	0.03	no
Boron	5	IMAC	29-Jan-19	1	0.005	no
Cadmium	0.005	MAC	29-Jan-19	1	<0.000015	no
Chromium	0.05	MAC	29-Jan-19	1	<0.002	no
Fluoride	1.5	MAC	20-Jan-15	1	0.1	no
Mercury	0.001	MAC	29-Jan-19	1	<0.00002	no
Selenium	0.01	MAC	29-Jan-19	1	<0.001	no
Sodium	200	AO	20-Jan-15	1	9.4	no
Uranium	0.02	MAC	29-Jan-19	1	<0.00005	no

NOTES:

Nitrate and nitrite values are maximum concentrations measured in quarterly samples.

MAC - ODWS maximum acceptable concentration

IMAC - ODWS interim maximum acceptable concentration

AO - ODWS aesthetic objective

Quarterly Nitrate / Nitrite Results (mg/L)

	Q1	Q2	Q3	Q4	Maximum	MAC
Date	Jan 29th	Apr 2nd	Jul 23rd	Oct 15th		
Nitrate	0.3	0.3	0.1	<0.1	0.3	10.0
Nitrite	<0.1	<0.1	<0.1	<0.1	<0.1	1.0

Table 7 – Schedule 24 Parameter Concentration Data

Parameter	Units	ODWS		Date Sampled	# of spls	Result	Limit Exceeded
		Limit	Type				
Alachlor	µg/L	5	IMAC	29-Jan-19	1	<0.3	no
Atrazine + Metabolites	µg/L	5	IMAC	29-Jan-19	1	<0.5	no
Azinphos-methyl	µg/L	20	MAC	29-Jan-19	1	<1	no
Benzene	µg/L	1	MAC	29-Jan-19	1	<0.5	no
Benzo(a)pyrene	µg/L	0.01	MAC	29-Jan-19	1	<0.005	no
Bromoxynil	µg/L	5	IMAC	29-Jan-19	1	<0.3	no
Carbaryl	µg/L	90	MAC	29-Jan-19	1	<3	no
Carbofuran	µg/L	90	MAC	29-Jan-19	1	<1	no
Carbon tetrachloride	µg/L	2	MAC	29-Jan-19	1	<0.2	no
Chlorpyrifos	µg/L	90	MAC	29-Jan-19	1	<0.5	no
Diazinon	µg/L	20	MAC	29-Jan-19	1	<1	no
Dicamba	µg/L	120	MAC	29-Jan-19	1	<5	no
1,2-dichlorobenzene	µg/L	200/3	MAC/AO	29-Jan-19	1	<0.5	no
1,4-dichlorobenzene	µg/L	5/1	MAC/AO	29-Jan-19	1	<0.5	no
1,2-dichloroethane	µg/L	5	IMAC	29-Jan-19	1	<0.5	no
1,1-dichloroethene	µg/L	14	MAC	29-Jan-19	1	<0.5	no
Dichloromethane	µg/L	50	MAC	29-Jan-19	1	<5	no
2,4-dichlorophenol	µg/L	900/0.3	MAC/AO	29-Jan-19	1	<0.1	no
2,4-dichlorophenoxy acetic acid	µg/L	100	IMAC	29-Jan-19	1	<5	no
Diclofop-methyl	µg/L	9	MAC	29-Jan-19	1	<0.5	no
Dimethoate	µg/L	20	IMAC	29-Jan-19	1	<1	no
Diquat	µg/L	70	MAC	29-Jan-19	1	<5	no
Diuron	µg/L	150	MAC	29-Jan-19	1	<5	no
Glyphosate	µg/L	280	IMAC	29-Jan-19	1	<25	no
Malathion	µg/L	190	MAC	29-Jan-19	1	<5	no
MCPA	µg/L	100	MAC	29-Jan-19	1	<10	no
Metolachlor	µg/L	50	IMAC	29-Jan-19	1	<3	no
Metribuzin	µg/L	80	MAC	29-Jan-19	1	<3	no
Monochlorobenzene	µg/L	80/30	MAC/AO	29-Jan-19	1	<0.5	no
Paraquat	µg/L	10	IMAC	29-Jan-19	1	<1	no
Pentachlorophenol	µg/L	60, 30	MAC/AO	29-Jan-19	1	<0.1	no
Phorate	µg/L	2	IMAC	29-Jan-19	1	<0.3	no
Picloram	µg/L	190	IMAC	29-Jan-19	1	<5	no
Polychlorinated Biphenyls (PCB's)	µg/L	3	IMAC	29-Jan-19	1	<0.05	no

Prometryne	µg/L	1	IMAC	29-Jan-19	1	<0.1	no
Simazine	µg/L	10	IMAC	29-Jan-19	1	<0.5	no
Terbufos	µg/L	1	IMAC	29-Jan-19	1	<0.3	no
Tetrachloroethylene	µg/L	30	MAC	29-Jan-19	1	<0.5	no
2,3,4,6-Tetrachlorophenol	µg/L	100/1	MAC/AO	29-Jan-19	1	<0.1	no

Table 7 – Schedule 24 Parameter Data (2)

Parameter	Units	ODWS		Date Sampled	# of samples	Result	Limit Exceeded
		Limit	Type				
Triallate	µg/L	230	MAC	29-Jan-19	1	<10	no
Trichloroethylene	µg/L	5	MAC	29-Jan-19	1	<0.5	no
2,4,6-Trichlorophenol	µg/L	5, 2	MAC, AO	29-Jan-19	1	<0.1	no
Trifluralin	µg/L	45	IMAC	29-Jan-19	1	<0.5	no
Vinyl Chloride	µg/L	1	MAC	29-Jan-19	1	<0.5	no

NOTES:

Samples for THM & HAA analysis collected from distribution sample hydrant
 THM and HAA MAC is based on 4-quarter running average

Quarterly THM Results (µg/L)

	Q1	Q2	Q3	Q4		
Date	Jan 29th	Apr 2nd	Jul 23rd	Oct 15 th	Average	MAC
Bromodichloromethane	3.0	2.0	6.0	6.0	4.3	
Bromoform	<5.0	<5.0	<5.0	<5.0	<5.0	
Chloroform	35.0	18.0	14.0	26.0	23.3	
Dibromochloromethane	<2.0	<2.0	<2.0	<2.0	<2.0	
Total THMs	38.0	20.0	21.0	33.0	28.0	100

Quarterly HAA Results (µg/L)

	Q1	Q2	Q3	Q4		
Date	Jan 29th	Apr 2nd	Jul 23rd	Oct 15 th	Average	MAC
Chloroacetic Acid	<4.7	<4.7	<4.7	<4.7	<4.7	
Bromoacetic Acid	<2.9	<2.9	<2.9	<2.9	<2.9	
Dichloroacetic Acid	19.2	9.1	6.8	10.6	11.4	
Dibromoacetic Acid	<2.0	<2.0	<2.0	<2.0	<2.0	
Trichloroacetic Acid	30.3	13.2	9.3	13.8	16.7	
Total HAAs	49.5	22.3	16.1	24.4	28.1	80

3.7 Distribution System Lead Testing

Lead can be present in drinking water systems as the result of corrosion of lead solder, lead in brass fittings/fixtures, or lead pipes in plumbing or building service lines. Although most of those sources of lead have been eliminated from modern construction materials, elevated concentrations are periodically detected in water samples collected in older neighborhoods where lead service lines still exist. As a result, in 2007 the Province imposed mandatory lead testing at all municipal drinking water systems. This precautionary testing was primarily focused on protecting the health of the vulnerable population which, in the case of lead contamination, is young children (<6 yr) and pregnant women. While drinking water is a minor contributor to blood lead levels, municipal lead testing helps identify potential sources of contamination and will provide opportunities to further improve the high quality of public water supplies.

From 2008 through 2010, a total of 120 samples were collected from residential and non-residential plumbing. Of those, only 6 exceeded the standard. Additional testing at the sites where the standard was exceeded clearly indicated that minimal lead remained in the water after flushing for as little as several seconds.

Residential lead testing was not required during 2011 and 2012 as past results from the Deseronto system demonstrated a very low health risk.

The lead sampling program resumed at a reduced rate in 2013, with results from all tested locations well below the ODWQS maximum acceptable concentration.

Based on the favorable past results, residential lead sampling is no longer required unless significant changes in other water characteristics are observed; specifically, pH and alkalinity. Testing of pH and alkalinity in the distribution system continues to be a semi-annual requirement while lead in the distribution system must be measured once every three years. Analytical data for distribution system lead, pH, and alkalinity from 2013 to 2019 are provided in Table 8.

Table 8 – Distribution Lead, pH, and Alkalinity

Sample Date	West Sample Hydrant			North Sample Hydrant			East Sample Hydrant		
	Lead mg/L	pH	Alkalinity mg/L	Lead mg/L	pH	Alkalinity mg/L	Lead mg/L	pH	Alkalinity mg/L
25-Feb-2013	0.00031	7.0	92	0.00050	7.0	92			
25-Sep-2013	0.00079	6.8	67	0.00092	6.8	67			
14-Jan-2014		6.9	86					6.9	86
12-Aug-2014		6.9	82					7.0	82
20-Jan-2015		7.0	94					7.0	96
07-Jul-2015		6.8	90					6.7	91
26-Jan-2016	0.00044	7.1	97				0.00032	7.1	97
26-Jul-2016	0.00067	6.6	82				0.00034	6.8	84
10-Jan-2017		7.4	89					7.3	89
11-Jul-2017		7.2	83					7.2	83
23-Jan-2018		7.3	91					7.3	91
17-Jul-2018		6.4	72					6.8	73
02-Apr-2019	0.00013	7.2	81	0.00009	7.2	78			
23-Jul-2019	0.00010	6.9	83	0.00016	6.9	106			
Limit / Objective	0.01	6.5 – 8.5	30 - 500	0.01	6.5 – 8.5	30 - 500	0.01	6.5 – 8.5	30 - 500

3.9 Microcystin Testing

Blooms of blue-green algae are common in the Bay of Quinte during warm summer and early fall months. When blue-green algae decays it releases toxic compounds called microcystins.

To monitor for microcystins in Deseronto drinking water, samples of both raw and treated water are sampled and tested weekly from June to October. Measureable concentrations of microcystins in the raw untreated Bay water are seasonally common but are typically below the drinking water standard of 1.5 µg/L as microcystin-LR. During 2019 the maximum concentration of microcystin-DM measured in untreated water was 1.95 µg/L on August 20, 2019. That result is similar to the maximum observed in 2018 (2.20 µg/L). Microcystin standard is based on microcystin-LR which is a small portion of the reported value as microcystin-DM.

Microcystins are removed through the Deseronto treatment process by oxidation (chlorine) and by

adsorption in the granular activated carbon filter media. The treatment process has been effective in removing microcystins from the raw water as it was not detected in any treated water sample collected in 2019.

3.10 Waste Clarifier Performance Monitoring

The waste clarifier treats the waste generated from the water treatment process including filter backwash, and sludge from the flotation process. Treated effluent from the waste clarifier is discharged to the Bay of Quinte. The waste clarifier was put back into service in July after completion of the upgrade construction. While out of service, all waste was pumped directly to the raw sewage wet well at the wastewater treatment plant.

Effluent from the waste clarifier, when in operation, is sampled at least once per month and tested for total suspended solids (TSS). The annual average concentration of TSS was 8 mg/L which is well below the maximum permitted average concentration of 25 mg/L. Flow to the waste clarifier during 2019 did not exceed the design capacity of 350 m³/d. Performance data for the waste clarifier is provided in Table 9.

Table 9 – Waste Clarifier Performance Data

Month	Avg. Flow (m ³ /d)	Max. Flow (m ³ /d)	TSS (mg/L)
January	o/s	o/s	o/s
February	o/s	o/s	o/s
March	o/s	o/s	o/s
April	o/s	o/s	o/s
May	o/s	o/s	o/s
June	o/s	o/s	o/s
July	42.0	44.2	<3
August	64.3	72.8	24
September	41.4	60.5	5
October	29.4	45.5	3
November	47.7	48.8	3
December	53.7	57.3	3
Maximum		72.8	24
Average	46.4		8
DWWP Limit			25

where:
 Avg. Flow - Average daily flow for each month.
 Max. Flow - Maximum day flow measured each month.
 TSS - total suspended solids
 DWWP TSS limit based on annual average of monthly spls

4 – System Maintenance and Improvements

Major upgrading of the water treatment plant commenced in May 2018 and was substantially completed in August 2019. The upgrades include:

- new low lift pumps and controls,
- replacement of the reactor clarifier with twin dissolved air flotation processes,
- replacement of 2 dual media filters and 2 granular activated carbon contactors with 3 conventional sand filters incorporating a granular activated carbon media cap, complete with backwash pump, air scour blower and piping and pressure controls for back-up backwash from the distribution system,
- replacement of motors and controls on 2 of 4 high lift pumps,
- replacement of the stainless steel pipe header from the high lift pumps to the distribution system, complete with a new in-plant isolation valve,
- new SCADA process control system,
- replacement of the low lift and treatment plant chlorine disinfection systems with associated monitoring instrumentation and controls,
- new lighting, and HVAC systems,
- refurbishment of the office, control room, lab, and lunch/meeting rooms,
- new MCC with automatic transfer switch to the emergency power generator,
- structural reinforcement, insulation, windows, doors, and cladding of the WTP building

The upgrades will address design deficiencies, remove existing capacity bottlenecks, and improve the overall efficiency and reliability of the treated water supply for the Town and neighbouring Mohawks of the Bay of Quinte (MBQ).

This project was 2/3rds funded by the Federal and Provincial governments under the Small Communities Fund. The remaining third was funded by the Town (65%) and the MBQ (35%), proportional to the capacity allocated to each community.